



Central Connecticut State University

Start with a Dream. Finish with a Future.

Purchasing Department

REQUEST FOR QUOTATION 2017-12
Carroll Hall Verint security cameras
Addendum #1 Dated August 17, 2016

The following are questions submitted related to this RFQ and their answers –

1. Is there a specified height for the (4) PTZ Cameras to be mounted?
ANSWER: Exterior of building 18FT above ground.
2. Where exactly will the network drops be located?
ANSWER: On the second floor. See revised drawing for locations.
3. If there is an IDF Room where is this located?
ANSWER: On the second floor. See revised drawing for location.
4. Can we schedule a walk through of Carroll Hall?
ANSWER: There is no walk through scheduled, however CCSU is an open, public campus. As this is mostly exterior work, interested parties may visit campus to inspect the exterior of the building. It is recommended that visitors stop at the CCSU Police Dept (1500 East Street) to obtain a parking pass first.

IMPORTANT NOTE –



Note that the awarded contractor shall also be responsible for providing licenses for the four new Verint cameras.

CCSU shall still be responsible for the camera recording assignments.

See attached revised RFQ form (pages 1 & 2 only) and use the revised pages in your bid response.

All other terms, conditions and specifications in the RFP remain the same.
End of Addendum #1

40' 30' 20' 10' 0' 10'




DATE	DESCRIPTION	BY
04	A2	

CLARENCE CARROLL HALL
20 DILORETO DRIVE
SECOND FLOOR, SECURITY PLAN

CENTRAL CONNECTICUT STATE UNIVERSITY

Office of the University Architect, Rm.#201, East Hall, 185 Stanley Street, New Britain, Ct, 06050, Tel.# 860/832-2711, Fax.# 860/832-2328



REQUEST FOR QUOTATION

This is NOT an
order to ship.

Please quote on the commodities or services listed below.

All prices must be FOB Destination.

You must show Unit Price, Amount and Total or bid may be rejected. The State of Connecticut is exempt from payment of Federal Excise taxes and the Connecticut Sales Tax. Do not include such taxes in bid prices. CCSU reserves the right to reject in whole or in part any or all bids submitted.

VENDOR NAME
ADDRESS

BID NUMBER –
2017-12
Rev1

BID DUE DATE:
Aug 25, 2016
3:00 PM

ISSUED BY (return to)

Central Connecticut State University
Purchasing Department
1615 Stanley Street
New Britain CT 06050-4010

DATE ISSUED:
Aug 9, 2016

SIGNED (for Agency)

Thomas Brodeur, C.P.M.

Prepared by:

Thomas Brodeur, C.P.M.
Director of Purchasing
Phone 860-832-2531

Purchasing Authority:
C.G.S. 10a-151b
C.G.S. 4a-52a

Carroll Hall: Provide, install and program four (4) Verint security cameras.
See page two for details and specifications.
No substitutions on named manufacturers – to match existing.

Total, delivered, installed, licensed and programmed \$ _____

Return bid to the CCSU Purchasing Department Marcus White Annex room 006, in a sealed envelope marked:
CCSU Bid 2017-12 due 3:00 PM on Aug 25, 2016

Contractors may submit questions or requests for clarification via email to brodeur@ccsu.edu. The deadline for submission of questions is 4:30 p.m., E.S.T., on Aug 17, 2016. Any answers, clarifications or corrections that change the scope of this RFQ will be issued as an addendum.

NOTE: CCSU may need to issue one or more addenda related to this RFQ. Such addenda shall be posted at <http://www.ccsu.edu/purchasing/currentBids.html>.

It shall be the responsibility of prospective contractors and other interested parties to familiarize themselves with the web site and visit it regularly during the RFQ process for updated information or addenda

Vendor Authorized Signature

Printed Name

Email Address

Telephone and Extension

FEIN _____

Date _____

Cash Discount Payment Terms ____ % ____ days, Net 30

CCSU RFQ 2017-12 rev1
Verint Security Cameras, installation and programming
Carroll Hall exterior

Awarded contractor shall be responsible for the following –

- Providing and installing four (4) Verint HD PTZ cameras (V5620PTZ-18DW-C)
- Providing and installing four (4) Verint Wall Mounts (WM-V5620PTZ)
- Providing and installing four (4) Verint Corner Mounts (CM-V5620PTZ)
- Providing and installing one (1) Altronix Power Supply (Vertiline8)
- Supplying and installing all necessary wiring to connect each camera back to existing data closet, including all necessary data and patch cables. *Pink shielded cat 6 cable is required.*
- Providing 12v power to the four cameras (All POE)
- Connecting and programming all four cameras to CCSU's Verint Nextiva 6.3 system *
- Adding all four cameras to CCSU's campus map
- Licenses for all four cameras
- Testing and commissioning of the new installations

* Provide with your bid response a copy of your Verint endorsement letter or certification.

CCSU shall be responsible for –

- IP Address for each camera
- Open data port, mapped for each camera
- Open patch panel slot
- Camera recording assignments

CCSU shall enter into a Contract with the awarded contractor for the services described herein. A Purchase Order issued by CCSU's Purchasing Office shall be issued once a signed contract is in place. Work cannot begin related to this RFQ until a valid Purchase Order is in place.